

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL					
MODEL NO:WGO1002P(X)		VOLTS:	208 1P	240 1P	
TAG: HKP-10C		HTR WATTS:	7125	9500	
PAGE 1 OF 2		HTR AMPS:	34.3	39.6	
EQUIPMENT MODEL NO		MCA	MOCP	MCA	MOCP
	DUAL CIRCUIT				
	GPC15M 24 - 48	43	45	49	50
	GPC15M(H) 36 - 60	43	45	49	50
	GPC(H)14H 24 - 60	43	45	49	50
	GPH13M 24 - 60	43	45	49	50
	GPH13M(H) 24 - 60	43	45	49	50
	SINGLE CIRCUIT				
	GPC13M 36	45	60	52	60
	GPC13M 48	49	60	56	60
	GPC13M 60	51	60	58	60
	GPC13(14)H 24	45	60	51	60
	GPC13(14)H 30,36,42,48,49	46	60	53	60
	GPC13(14)H 60	48	60	54	60
 WARREN TECHNOLOGY					

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL					
MODEL NO:WGO1002P(X)		VOLTS:		208 1P	240 1P
TAG: HKP-10C		HTR WATTS:		7125	9500
PAGE 2 OF 2		HTR AMPS:		34.3	39.6
EQUIPMENT MODEL NO		MCA	MOCP	MCA	MOCP
	SINGLE CIRCUIT				
	GPH15M 24			71	80
	GPH15M 30			73	80
	GPH15M 36,43			76	80
	GPH15M 49			80	90
	GPH15M 60			92	100
	GPH13(14)H 24			68	70
	GPH13(14)H 30			70	80
	GPH13(14)H 36			74	80
	GPH13(14)H 42			76	80
	GPH13(14)H 48			79	80
	GPH13(14)H 60			90	100
 WARREN TECHNOLOGY					