

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL					
MODEL NO:WGO1002B(X)		VOLTS:	208 1P	240 1P	
TAG: HKR10C		HTR WATTS:	7125	9500	
Page 1 of 2		HTR AMPS:	34.3	39.6	
EQUIPMENT MODEL NO		MCA	MOCP	MCA	MOCP
	AR, ARUF, ARPF, ARPT 18/24, MBR 0800	45.0	45	51.6	60
	AER 24, AEPT 24,AEPF 18	45.0	45	51.6	60
	AR,ARUF 30/32/36	46.1	50	52.8	60
	ARPF, ARPT 30/36	46.1	50	52.8	60
	AER 30/36, AEPT 30/36,AEPF 30/31/42	46.1	50	52.8	60
	AR,ARUF42/48/49	47.4	50	54.0	60
	ARPF, ARPT 42/48	47.4	50	54.0	60
	AER 48, AEPT 48	47.4	50	54.0	60
	AR, ARUF 60/61,ASPF 18/30/31/42	48.6	50	55.3	60
	AER 60, AEPT 60	48.6	50	55.3	60
	ARPF 61, ARPT 60	48.6	50	55.3	60
	GPC/H1324,30,36,42,48,60	50.0	50	57.0	60
	MBE 1200/1600/2000	47.3	50	53.9	60
	MBR 1200/1600/2000	47.8	50	54.4	60
 WARREN TECHNOLOGY					

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL					
MODEL NO:WGO1002B(X)		VOLTS:	208 1P	240 1P	
TAG: HKR10C		HTR WATTS:	7125	9500	
Page 2 of 2		HTR AMPS:	34.3	39.6	
EQUIPMENT MODEL NO		MCA	MOCP	MCA	MOCP
	MBVC 12	47.1	50	53.7	60
	MBVC 16	49.1	50	55.7	60
	MBVC 20	48.6	50	55.2	60
 WARREN TECHNOLOGY					