

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL					
MODEL NO:WGO0502B(X)		VOLTS:	208 1P	240 1P	
TAG: HKR05C		HTR WATTS:	3560	4750	
Page 1 of 2		HTR AMPS:	17.1	19.8	
EQUIPMENT MODEL NO		MCA	MOCP	MCA	MOCP
	AR,ARUF18/24,ARPF, ARPT 24	23.5	25	26.9	30
	AER 24. AEPT 24, ASPF 18	23.5	25	26.9	30
	AR,ARUF 30/32/36	24.6	25	28.0	30
	ARPF, ARPT 30/36,MBE1200,MBR 0800/1200	24.6	25	28.0	30
	AER 30/36, AEPT 30/36,AEPF 18/30/31	24.6	25	28.0	30
	AR,ARUF 42/48/49	25.9	30	29.3	30
	ARPF, ARPT 42/48	25.9	30	29.3	30
	AER 48, AEPT 48	25.9	30	29.3	30
	AR, ARUF 60/61,ASPF 30/31/42	27.1	30	30.0	30
	AER 60, AEPT 60	27.1	30	30.0	30
	ARPF 61, ARPT 60	27.1	30	30.0	30
	GPC/H1324,30,36,42,48	26.3	30	29.6	30
	MBE2000,MBR 1600/2000	26.3	30	29.6	30
	MBE1600, AEPF 42	27.0	30	30.4	35
 WARREN TECHNOLOGY					

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL					
MODEL NO:WGO0502B(X)		VOLTS:		208 1P	240 1P
TAG: HKR05C		HTR WATTS:		3560	4750
Page 2 of 2		HTR AMPS:		17.1	19.8
EQUIPMENT MODEL NO		MCA	MOCP	MCA	MOCP
	MBVC 12	25.7	30	29.0	30
	MBVC 16	27.7	30	31.0	35
	MBVC 20	27.2	30	30.5	35
	GPH14 24,30,36,42,48,60 H	21	25	25	25
	SINGLE POINT				
	GPH14 24H			43	50
	GPH14 30H			45	50
	GPH14 36H			49	60
	GPH14 42H			51	60
	GPH14 48H			54	60
	GPH14 60H			62	80
 WARREN TECHNOLOGY					