

**REFRIGERANT CHARGING UPDATE:** The manual packed with your system may contain an incorrect additional charge table on Page 5. **Please completely ignore the boxed data below.** Adjust your refrigerant levels based *strictly* on your linear lineset length.

- **What to Ignore:** Any instruction or table specifying a mandatory "**additional refrigerant combination charge.**"
- **What to Do: Completely ignore it.** This extra combination charge does not apply to your system.
- **Standard Procedure:** Proceed with your standard charging protocol, adjusting your refrigerant levels based strictly on the linear length of your lineset.

**\* For R454B refrigerant charge amount and minimum room area:**

The machine you purchased may be one of the types in the table below. The indoor and outdoor units are designed to be used together. Please check the machine you purchased. The minimum room area of operating or storage should be as specified in the following table:

Products series	Model	Indoor unit	Outdoor unit
<b>2GenAHU</b>	18K(208/230V)	BNGFA18DH2	BNG3A18UCN
	24K(208/230V)	BNGFA24DH2	BNG3A24UCN
	30K(208/230V)	BNGFA30DH2	BNG3A30UCN
	36K(208/230V)	BNGFA36DH2	BNG3A36UCN
	48K(208/230V)	BNGFA48DH2	BNG3A48UCN
	60K(208/230V)	BNGFA60DH2	BNG3A60UCN
<b>3GenAHU</b>	18K(208/230V)	BNG3A18DH3	BNG3A18UCN
	24K(208/230V)	BNG3A24DH3	BNG3A24UCN
	30K(208/230V)	BNG3A30DH3	BNG3A30UCN
	36K(208/230V)	BNG3A36DH3	BNG3A36UCN
	48K(208/230V)	BNG3A48DH3	BNG3A48UCN
	60K(208/230V)	BNG3A60DH3	BNG3A60UCN

[ \*1 ]: For this product combination, an additional 0.60kg/21.16 oz of refrigerant is required.  
 [ \*2 ]: For this product combination, an additional 0.65kg/22.93 oz of refrigerant is required.

Ignore the information in the red box if it is present in your installation instructions.

If you have any questions please call 1-800-865-5931 and speak to tech support.