

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WGO0802B(X)	VOLTS:	208 1P	240 1P	
TAG: HKR08C	HTR WATTS:	5250	7000	
	HTR AMPS:	25.2	29.2	
EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
AR,ARUF18/24,ARPF,ARPT24	33.6	35	38.6	40
AER 24,AEPT 24,AEPF 18/30/31	33.6	35	38.6	40
AR,ARUF 30/32/36	34.8	35	39.8	40
ARPF, ARPT 30/36.ASPF 18	34.8	35	39.8	40
AER 30/36, AEPT 30/36	34.8	35	39.8	40
GPC/H1324,30,36,42,48	36.4	40	40.0	40
ARUF/ARPF/ARPT/AEPT 48,60,61,AEPF 42	36.9	40	41.9	45
ARUF/ARPF/ARPT/AEPT 42,43,ASPF 30/31/42	35.8	40	40.8	45
MBE 1200, MBR 0800/1200	34.5	35	39.5	40
MBE 1600/2000, MBR 1600/2000	36.4	40	41.4	45
MBVC 12	35.8	40	40.7	45
MBVC 16	37.8	40	42.7	45
MBVC 20	37.3	40	42.2	45

